पत्रांक ....530..... /राँची – 17

कार्यालय अधिष्ठान अग्निशाम पदाधिकारी , राँची ।

दिनांक : 23/10/17 ,

प्रेषक,

अधिष्ठान अग्निशाम पदाधिकारी ,
डोरण्डा , राँची।

सेवा में ,

प्राचार्य ,
सच्चिदानन्द ज्ञान भारती मॉडल स्कूल ,
108 , कुसई , डोरण्डा , राँची।

विषयः अनापत्ति प्रमाण–पत्र देने के संबंध में।

महाशय,

आपके स्कूल का निरीक्षण किया गया, जिसमें अग्नि से होने वाला घटना को रोकने हेतु निम्नलिखित व्यवस्था पाया गया –

1. सभी तरह के अग्निशामक यंत्र सही पाया गया।
   वर्ष 2018–19 हेतु आपको निम्नलिखित शर्तों के साथ अनापत्ति प्रमाण–पत्र दिया जाता है।

2. वर्ष में सभी अग्निशामक यंत्रों का रिफिलिंग करायेंगे।

3. प्रत्येक वर्ष अनापत्ति प्रमाण – पत्र प्राप्त कर लेंगे।

विश्वासभाजन

Sachidanand Gyan Bharti Trust
Managing Trustee

23/10/17
अधिष्ठान अग्निशाम पदाधिकारी,
डोरण्डा, राँची।
अधिष्ठान अग्निशाम पदाधिकारी
डोरण्डा, राँची

Sumita Sen.

PRINCIPAL
SACHIDANAND GYAN BHARTI
MODEL SCHOOL

Sellers Fire Services
Suite 1 B, Ground Floor, Mahabir Tower,
Opp. GEL Church Shopping Complex,
Main Road, Ranchi 834 001
Tel: 920 4858 605 / 993 4315 118 / 920 4858 600
E : sellersranchi@gmail.com
www.sellersranchi.com

July 15, 2026

TO WHOM IT MAY CONCERN

This is to confirm that we have serviced and refilled the following Fire Extinguishers, of M/s. Shachidanand Gyan Bharti Model School, Kusai Colony, Doranda, Ranchi 834 002, Jharkhand, on July 11, 2026:

ABC type, 2 Kgs. Capacity.	6 nos.
ABC type, 6 Kgs. capacity.	4 nos.
Water CO2 type, 9 Ltrs.capacity.	2 nos.
DCP type, 5 Kgs. capacity.	7 nos.

The performance guarantee for these equipments is good working condition & valid for one year from date of refilling subject to proper storage and correct usage. The next service & refilling of above Fire Extinguishers will become due in July 10, 2027.

For Sellers Fire Services

Sellers Fire Services Estd 2012 Ranchi

Sanjeew Kumar
920 4858 605

Sellers
TOTAL FIRE PROTECTION
MEMBER : FIRE AND SECURITY ASSOCIATION OF INDIA

Sumita Sen.
PRINCIPAL
SACHIDANAND GYAN BHARTI
MODEL SCHOOL

Sachidanand Gyan Bharti Trust
Managing Trustee